

• **Polymerisation unit
Wapo-Mat III**



• **USER MANUAL**

Dear customer,

Thank you for choosing a product from the Wassermann range. Wassermann Dental-Maschinen incorporates the highest standards of quality and the latest technology. In order to enjoy maximum performance and years of trouble-free operation, please read this user manual carefully before you connect this device and start work, and operate the device according to the recommended guidelines. The operation safety and the functionality of this device can only be guaranteed if you follow both the general safety guidelines and the applying laws to prevent accidents as well as the precautions given in this user manual. We are not liable for any damages which occur due to inappropriate usage or faulty operation of this device.



Make sure that anyone using this device has read and understood this user manual.

Keep this user manual in a safe place where it can be referred to as required at any time.

Company address:

Wassermann Dental-Maschinen GmbH

Rudorffweg 15-17

D-21031 Hamburg, Germany

Phone. : +49 (0)40 / 730 926 – 0 Fax.: +49 (0)40 / 730 37 24

E-mail: info@wassermann-dental.com

URL: <http://www.wassermann-dental.com>

Contents

1 Features.....	4
2 Safety guidelines.....	4
2.1 Safety symbols used in this manual.....	4
2.2 Safety guidelines.....	5
2.3 Responsibility for operation or damage.....	5
3 Application.....	5
4 Before starting.....	6
4.1 Transport.....	6
4.2 Installation.....	6
4.3 Storage.....	6
5 Installation / Commissioning / Menufunctions.....	7
6 Operation.....	13
6.1 General operating instructions.....	13
6.2 Operation.....	14
7 Troubleshooting / Correccting errors.....	15
8 Maintenance.....	16
8.1 Cleaning.....	16
8.2 Maintenance.....	17
8.3 Repairs.....	17
8.4 Spare parts.....	17
8.5 Service hotline.....	17
8.6 Scope of delivery / Accessories.....	17
8.7 Warranty.....	18
9 Technical specifications.....	18
10 EC Conformity Certificate.....	19

1 Features

- compact benchtop unit for long-time and boiling polymerisation
- fully automatic program sequence, capable to handling 9 flasks simultaneously
- Touchscreen-multifunctional display with minute and degree settings, remaining time reading
- powerful, electronically controlled heater for optimal water temperature, low water level indicated visually and audibly
- energy-saving tank thermal insulation
- low maintenance, easy to clean
- all stainless steel construction

2 Safety guidelines

2.1 Safety symbols used in this manual



Warning!

This is a warning of risk situations and dangers.

Failure to observe this warning could be life-threatening. These warnings has to be observed.



Information!

This symbol draws your attention to specific features that has to be observed.

2.2 Safety guidelines

Configuring and operating this equipment requires **precise knowledge** and **observance** of the instructions in this **user manual**. The equipment is designed only for its intended application.



WARNING:

Servicing and repairs should be carried out only by authorised specialists.
Disconnect the power plug before starting any maintenance work.



Make sure that the equipment is connected to the correct power source.

2.3 Responsibility for operation or damage

The responsibility for operating the device lies exclusively with the owner or user if said device is incorrectly serviced, maintained or altered by persons not employed by an authorised dealer or if the device is used in a manner contrary to its specified purpose.

The unit has to be maintained and operated in accordance with this user manual. Wassermann Dental-Maschinen GmbH is not responsible for damage arising from the **nonobservance** of these instructions.

Warranty and responsibility provisions contained in the sales and supply conditions of Wassermann Dental-Maschinen GmbH are not extended by these instructions.

3 Application


The Wapo-Mat III is designed for water-bath polymerisation. All readily available plastics can be polymerised fully automatically, slowly (up to 99 hours), and at high temperature (99°C).

Only use the device for this type of application.

4 Before starting

4.1 Transport

Before transporting the unit, ensure that it has been unplugged from the power socket. Make sure that it is packed correctly in order to avoid accidental damage.

-  Be sure to check for any transport damage when unpacking the goods. Note down any damage if found.

4.2 Installation

Remove all packing material and place the unit on an even and stable surface. Check the parts included in delivery (see 8.5).



Place the unit so that the work area is freely accessible and operation is not restricted. (Please consider the structural dimensions).



Do not place the unit outdoors.

Before start-up, be sure the device reaches room temperature.



We strongly recommend to install the unit firmly to the discharge system, since it is equipped with an automatic water overflow discharge system, i.e. too much filled water runs out automatically, even when the discharge cock is closed. Furthermore complete emptying for cleaning purposes etc. is thus simplified.

4.3 Storage

In case of long-term storage, the unit must be protected against humidity and dust.


5 Installation / Commissioning / Menufunctions



Before commissioning, please install the following connections:

Firmly clamp the supplied drainage hose to the device and ensure there is a suitable drainage facility.


Insert the plug into the socket – make sure that the voltage information between the device and the mains network is identical. Fill the device with mains water to above the white plastic ring in the container (max. 18.5 litres). Switch on the mains switch (green rocker switch). Symbol **(A)** must not appear.



Water deficit


Make sure you define the device's main parameters before switching it on. These settings are performed in the set-up menu **(3)**. Familiarise yourself with the many options which the system offers before starting polymeration. This applies in particular to functions **(7)** and **(14)**.

The Set-Up Menu




The Set-Up Menu Page 1

Make the following settings in the set-up menu:



The Set-Up Menu Page 2




Description of functions 6 - 14

6a Program Parameters

Defines the parameters for the program temperature and time. Touch the numbers to change the values. It is possible to store up to three polymerization steps # 1-3.

#	°C	h	
1	70°C	6:30h	▶
2	--°C	--:--h	↩
3	95°C	1:30h	↩

Polymerization Step 1:




Examples of the Steps 2 and 3:



Touch the arrow to start the polymerization. Interrupt or cancel the program using Start/Stop.

6b) Polymerization



7) Preheating Temperature

Defines the target temperature once the main switch has been activated.

The preheat temperature also applies to waiting times and rest periods. Default: 65°C




If the programme temperature selected is higher, the temperature falls back to this value when the programme ends.



After defining the desired mode it may make sense (14) to adjust the preheat temperature of the programme temperature. This avoids long heating up or cooling down phases.

8) Timer. This defines the weekday activation and deactivation times.



Programs running currently have a higher priority; they are not switched off until complete.

⑩ Sleep button display.

WAPO-MAT

 MO. 07.01.2013
19:05

 AUTO-ON: Tu. 06:30


Press the Sleep button to switch the system to sleep mode.

⑪ Definition of calibration method


DEF 
 CAL 

DEF: Default (calibrated for mains water)

CAL Calibration (only necessary for extreme deviations in water quality)




Drain water




Replenish water.

This measure defines the conductance of the water!

12 Choose between °C Celsius and °F Fahrenheit




13 Pictogram for the sequence in time and date function.



14 Choice of working mode

Defines whether the time should start immediately or once the heating value has been reached.



(a) (Default) Unit heats up to the temperature programmed via 6b. After reaching this value, the result measured is validated by a control cycle. If the value is confirmed, the polymerization will start.

(b) The programmed polymerization starts immediately.

6 Operation

6.1 General operating instructions

All recommendations to operate the device, whether verbal or written, are based on our experience and tests and can therefore only be considered reference points.



The Wapo-Mat III is protected against dry running in order to prevent the heating from burning out (flashing symbol: display on the left). While the program is running, an alarm sounds when there is insufficient water. Take care that the water level is always above the white plastic ring (see in the housing), as the heating and the program will otherwise shut down automatically! An additional safeguard protects the heating against overheating; it is automatically deactivated at above 99°C.




Wear heat-retardant gloves when working with the Wapo-Mat III.



Unplug the device if it is not in use for a longer period.


6.2 Operation

- Fill the work device with mains water to above the white plastic ring in the container (max. 18.5 litres).
- Activate main switch (green rocker switch).
- Check the water level – the low water alarm (A) must not flash.
- Place prepared cuvettes in the device clamp.
- The polymerization is started by touching the symbol (6b) or alternatively via the parameter menu (6a)
- After the polymerizations process has ended, the temperature falls/rises to the preset temperature again. (7)



7 Troubleshooting / Correcting errors

Fault	Likely cause	Likely solution
Wapo-Mat III does not heat up	Dirty level sensor	Clean level sensor
	Water level too low	Add water
Water-level LED comes on and warning tone sounds fig.: 1.	Dirty level sensor	Clean level sensor
	Water level too low	Top up water until control light goes off
Multi-function display not working correctly	Variations in mains voltage (220-240 V / 50/60 Hz)	Turn off main switch and turn on again in about 1 minute.
	Re-calibrating the touch display	Turn the unit on and while the Wassermann logo appears tap the touch display twice. This will take you to the self-explanatory touch panel calibration process. Fig.: 2-3
Programme not starting although set temperature has been reached.	In mode (a) the unit intentionally overheats by 1°C and waits briefly to validate the value.	This is not a fault, please wait roughly 45 sec.

 If the above recommendations do not solve the problem, contact your dental depot or our service department.




Figure 1



Figure 2




Figure 3

8 Maintenance

8.1 Cleaning



Pull out the mains plug before maintenance work.

The **model plate** must always be legible and must not be removed.



Clean the outside of the unit and any accessories with a sponge and/or a soft cloth and mild detergent.

The equipment should be cleaned regularly (ie, clean every 4 weeks with Kalk-Ex) to guarantee problem-free operation.

Quantity: approx. 300ccm Kalk-Ex per full tank (18.5 litres water).

If there is considerable limescale present, increase the amount of Kalk-Ex appropriately.

The *initial supply* of Kalk-Ex comes with the machine.

Clean the level sensor (white plastic ring) in the tank using a nailbrush, for example.



Leave KALK-EX to work for a maximum 12 hours. Then drain the tank and rinse thoroughly.



Please clean the water level sensor every 14 days with a brush.

8.2 Maintenance

The Wapo-Mat III does not require any special maintenance. You just need to keep it clean.

8.3 Repairs



Servicing or repairs to the equipment must only be carried out by trained technicians. Only **original Wassermann spares** are to be used. Responsibility for the product is voided if altered by unauthorised persons or if inappropriate components are installed.

8.4 Spare parts

If necessary please contact our service hotline phone.

8.5 Service hotline


0049 (0)40 / 730 926 - 0

8.6 Scope of delivery / Accessories

Included in delivery	Item no.:
PVC hose 19 x 4 (3/4") - 1500 mm long	320030
Hose protector Ø 20 – 32 x 12,2	322017
Kalk-Ex - 1000 ccm	655002

Accessories:	Item no.:
PVC hose 19 x 4 (3/4") - 1500 mm long	320030
Kalk-Ex - 1000 ccm	655002

8.7 Warranty

 The warranty period for our equipment is 12 months. If faults occur within the warranty period, contact your dental depot or get in touch directly with our service department.

Your equipment should only be operated in perfect condition. If faults occur which could harm operators or third parties, the unit should not be used until it has been fixed.

This warranty does not cover damage caused by improper use, external mechanical causes, transport damage or interference with the unit by unauthorized persons.

9 Technical specifications

Wapo-Mat III	Item no.: 170980
Voltage:	220–240 V / 50/60 Hz
Power consumption:	8 A
Output:	1800 W
Overall dimensions: Width x Height x Depth	330 x 460 x 530 mm
Weight:	18,5 kg
Noise emission:	≤ 70 dB (A)
Capacity :	18,5 l

 **We reserve the right to make technical changes.**

10 EC Conformity Certificate

in accordance with 2006/95/EG (low-voltage guidelines) and 2004/108/EG (EMV guidelines) and 2006/42/EG (machinery guidelines)

Manufacturer:	W A S S E R M A N N Dental-Maschinen GmbH Rudorffweg 15 - 17 D-21031 Hamburg	Product description:	Polymeriser for dental applications
Model:	Wapo-Mat III	Item no.	170980
Applicable standards	DIN EN 61010-1 DIN EN 61000-6-3 DIN EN 61000-6-1 DIN 45635-1 DIN EN 60335-1		

Hiermit wird bestätigt, dass die oben bezeichnete Maschine den genannten EG-Richtlinien entspricht. Diese Erklärung wird ungültig, falls die Maschine ohne unsere Zustimmung verändert wird.

This is to confirm that the above mentioned machine complies with the described EC rules. This declaration becomes invalid if the machine is modified without our approval.

Cette machine est conforme aux normes en vigueur de la Communauté Européene. Cet avis est nul et non avenant si cette machine est modifiée sans notre accord.

Esta máquina, anteriormente mencionada, cumple con los límites requeridos por el reglamento EC. Ahora bien, esta declaración quedará invalidada en caso de realizar modificaciones al aparato sin nuestra aprobación.

Hiermee wordt bevestigd dat bovengenoemde machine voldoet aan de voorgeschreven EU normen. Deze verklaring verliest geldigheid als er zonder onze uitdrukkelijke toestemming wijzigingen aan de machine worden aangebracht.

Ort, Datum: Hamburg, den 10.10.14

Firmenstempel :



Unterschrift : _____
Wilfried Wassermann
(Managing Director)

Wassermann Dental-Maschinen GmbH
Rudorffweg 15-17 · D-21031 Hamburg
Tel.: +49 (0)40 730 926-0 · Fax: +49 (0)40 730 37 24
info@wassermann-dental.com